

RECEIVED
FEB - 5 2018



FILE COPY

COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE

13901 Crown Court, Woodbridge, Virginia 22193

(703) 583-3800

www.deq.virginia.gov

Matthew J. Strickler
Secretary of Natural Resources

David K. Paylor
Director

Thomas A. Faha
Regional Director

February 28, 2018

Mr. Joseph Schiebel
Caroline County Dept of Public Utilities
P.O. Box 424
Bowling Green, Virginia 22427

**RE: PC#2017-3054; CASE CLOSED; Frog Level Volunteer Rescue Squad
29415 Richmond Turnpike, Ruther Glen, Caroline County 22546**

Dear Mr. Schiebel:

Following a review of the referenced file and based upon the information you have submitted regarding current site conditions, the Department of Environmental Quality (DEQ) has determined that petroleum contamination levels at this site do not represent an identified risk to human health and the environment. Therefore, this petroleum contamination case is closed and further corrective action related to this release is not required.

Please be advised, however, that should further environmental problems occur, which the DEQ determines are related to this release, the DEQ reserves the right pursuant to Virginia Law and Regulations to require additional investigation and/or corrective action.

Although no further corrective action is required related to this release, the following items may need to be addressed:

- Any groundwater monitoring wells installed as a result of this release must be properly closed in accordance with Section 5.8 and Appendix C of the DEQ Storage Tank Program Technical Manual.
- Any removed, closed-in-place, existing or new regulated underground storage tank (UST) must be registered with the DEQ. A UST Notification form (Form 7530-2) must be completed and sent to the DEQ at the above address. Completion of this form is not required if your tank(s) is currently registered and the registration is up-to-date. Certain types of tanks, such as tanks which contain heating oil that is used to heat the premises where the tank is located and tanks with a capacity of 1100 gallons or less which contain motor fuel for noncommercial purposes, are not required to be registered.


PC#2017-3054

- Any aboveground storage tank (AST) with a capacity greater than 660 gallons that contains petroleum may need to be registered with the DEQ. For more information, please contact the Petroleum Storage Tank Inspection Program at 703-583-3820 or by accessing the Virginia DEQ Web site @ www.deq.virginia.gov.

If you are eligible for and plan to seek reimbursement from the Virginia Petroleum Storage Tank Fund, you have **two years** from the date of this letter to apply for reimbursement. This includes reimbursement for costs to properly abandon monitoring wells.

If you have any questions or need additional information, please feel free to contact Susan Tiffany at (703) 583-3829.

Sincerely,



Randy Chapman
Environmental Manager
Remediation

caseclos.doc

cc: Email to rford@daa.com
File(009590)