



# GEORGIA

DEPARTMENT OF NATURAL RESOURCES

## ENVIRONMENTAL PROTECTION DIVISION

**Richard E. Dunn, Director**

**Agricultural Permitting Unit**

531 Main Street, Suite D

Tifton, Georgia 31794

229-391-2400

April 4, 2023

ROLEBO LLC  
PO BOX 131  
CAMILLA, GA 31730

**Re: Low Flow Protection Plan Audit**

Dear Permittee,

We recently performed routine audits of applicants and permit-holders who require a Low Flow Protection Plan as part of their permit. During these visits, we noticed your surface water withdrawal source was void of any staff gauges, monitoring stations, or other devices used to measure water flow and depth. Attached is a guide for Low Flow Protection plans and your submitted plan (if you already have one on file). The following details can help you locate the source we visited:

**County:** Randolph

**Source ID:** A89-120-0061

**Given Name:** Whatley Pond

**Coordinates:** (84.724675°W 31.723844°N)

If at any time the flow immediately downstream of the pump intake or pond outflow is less than the low-flow amount (711.846 GPM or 1.586 CFS), you must discontinue pumping until flow returns above, or equal to, the minimum low-flow level.

If you do not have a Low Flow Protection Plan in place, please follow the guide instructions on how to create one or contact your County Extension Agent so one can be submitted immediately.

You may contact your auditor directly with any questions at 229-391-2400 or via email at [kavin.towne1@dnr.ga.gov](mailto:kavin.towne1@dnr.ga.gov).

Sincerely,

*Kavin Towne*, Environmental Compliance Specialist  
Agricultural Permitting Unit