

# Riverbend Soil Consulting, Inc.

P.O. Box 2879

Rome, GA 30164-2879

Phone (706) 234-9444

FAX (706) 291-2914

## Soil Analysis Report

Client: Steve Slocumb

Phone #: \_\_\_\_\_

Client Address: \_\_\_\_\_

Cell/Pager #: \_\_\_\_\_

Site Location: Site C Whitecliff Drive

County: Gilmer

Level of Study: 3

(1-Reconnaissance, 2-Preliminary, 3-High Intensity, 3ss-Special Study)

Job Number: \_\_\_\_\_

7555

## SERIES DESCRIPTIONS

Date Evaluated:

September 18, 2024

Test Hole Number	#1	#2	#3	#4	#5	#6
Series Name	Cowee	Evard	Cowee	Evard		
Slope (Percent)	20%	15%	18%	18%		
Bedrock Depth (inches)	soft at 38" hard >48"	>60"	soft at 36" hard >48"	>60"		
Seasonal High Water Table	>60"	>60"	>60"	>60"		
Suitability Code	A	A	A	A		
Estimated Percolation Rate	45	45	45	45		
Optimum Percolation Depth	24"	24-36"	24"	24-36"		
Hydraulic Loading Rate						


Additional Comments: \_\_\_\_\_

Soil Classifier: \_\_\_\_\_



LEVEL 3 SOILS ANALYSIS FOR:  
STEVE SLOCUMB  
SITE "C"  
WHITECLIFF DRIVE  
GILMER COUNTY, GA  
9-18-2024  
JOB #7555

RIVERBEND SOIL CONSULTING  
P.O. BOX 2879  
ROME, GA 30164-2879  
706-234-9444



SITE "C"

SOIL SURVEY BOUNDARY

EVARD  
15-25%

10

COWEE  
15-25%

9

COWEE  
15-25%

11

12

EVARD  
15-25%

POTENTIAL  
HOUSE  
SITE



