



**Community
Environmental
Laboratories, Inc.**

MDE-CERTIFIED
WATER TESTING
LABORATORY (255)

RESIDENTIAL AND COMMERCIAL WATER TESTING

Built on Science...Growing on Trust

To: Ron Hanks
2804 Forge Hill Rd.
Bel Air, MD 21015

Report # D-21-856
March 30, 2021

Submittee Water: Ron Hanks
Sample Address: 2804 Forge Hill Rd.
Bel Air, MD 21015

Sample Location: Powder Room
Treatment/Filter systems installed: None
Well Type: Drilled
Well Cap: 2- Pieces (Vermin Proof)
Well Tag #: No Tag

Sampled by: Nicol Stricker, Cert # 6715NM
Community Environmental Laboratories, Inc.

Chain of Custody (COC)

	<u>Date</u>	<u>Time</u>	<u>Chlorine Residual</u>
Collected	03/29/21	0954	Free <0.10 mg/L
Released	03/29/21	1420	Total <0.10 mg/L
Received	03/29/21	1420	

Analytical Results

<u>Parameter</u>	<u>Method</u>	<u>Results</u>	<u>Pass/Fail</u>	<u>EPA Prim./Sec. MCL*</u>
Bacteria				
Total Coliform	9223	<i>Negative</i>	Pass	None present, (Primary)
E- Coli	9223	<i>Negative</i>	Pass	None present, (Primary)
Nitrate-N	4500-NO3	<i>5.23 mg/L</i>	Pass	<10.0 mg/L, (Primary)
Turbidity	2130 B	<i><1.00 NTU</i>	Pass	<10.0 NTU, (Primary)
Sand	vis.	<i>Absent</i>	Pass	None present, (Secondary)
pH	150.1	<i>5.63</i>	N/A	ideal range 6.5-8.5 (Secondary)

Samples were analyzed as received.

*U.S. Environmental Protection Agency's Primary/Secondary Maximum Contaminant Levels.

Reported by: David Klunk
David Klunk, B.S., M.S.B; Lab Director