


Certificate of Analysis

Report Date: October 9, 2023
Sample ID#: 23-0465
Client: Jay Edwards Auction
Property Tested: 11225 Arbutus Avenue
Bradshaw, MD 21087
County: Baltimore
Sampler ID: 1630 BW
Collection Location: Bathroom Tap
Date/Time Collected: 10/5/23 at 1:20 pm
Date/Time Relinquished: 10/5/23 at 4:45 pm

Samples Iced: Yes
Residual $CL_2 < 0.1$ mg/L: Yes

<u>Test Parameter:</u>	<u>Method:</u>	<u>^MCL/*SMCL</u>	<u>Result:</u>	
Nitrate as N	SM 4500D	10 mg/L as N	1.7 mg/L as N	PASS
Turbidity	EPA 180.1	10 NTU	<1.0 NTU	PASS
pH	EPA 150.1	*6.5-8.5 Units	6.1 Units	**
Sand		Negative	Negative	
Total Coliform	SM 9223B	Absent	Absent	PASS
E. Coli	SM 9223B	Absent	Absent	PASS



Kristy Whipperman
MD Lab 328

CASWELL
^MCL- Maximum Contamination Level
*SMCL- Secondary Maximum Contamination Level
**A non-enforceable parameter that may cause cosmetic or aesthetic effects (such as taste, color, or odor) in drinking water.

Based upon Coliform Bacteriological Standards, the above results indicate that, at the time the sample was collected, this water sample was safe for drinking purposes.