


Certificate of Analysis

Report Date: December 11, 2023
Sample ID#: 23-0521
Client: Jay Edwards
Jay Edwards Auctioneers
Property Tested: 11944 Jerusalem Road
Kingsville, MD 21087
County: Baltimore
Sampler ID: 1630 BW
Collection Location: Kitchen Tap
Date/Time Collected: 12/8/23 at 11:40 am
Date/Time Relinquished: 12/8/23 at 3:00 pm
Conditioning/Treatment: None
Well Tag Number: Not available
Well Condition: Well in pit
Samples Iced: Yes
Residual $CL_2 < 0.1$ mg/L: Yes

<u>Test Parameter:</u>	<u>Method:</u>	<u>^MCL/*SMCL</u>	<u>Result:</u>	
Nitrate as N	SM 4500D	10 mg/L as N	5.2 mg/L as N	PASS
Turbidity	EPA 180.1	10 NTU	1.3 NTU	PASS
pH	EPA 150.1	*6.5-8.5 Units	5.9 Units	**
Sand		Negative	Negative	
Total Coliform	SM 9223B	Absent	Absent	PASS
E. Coli	SM 9223B	Absent	Absent	PASS



Kristy Whipperman
MD Lab 328

^MCL- Maximum Contamination Level
*SMCL- Secondary Maximum Contamination Level
**A non-enforceable parameter that may cause cosmetic or aesthetic effects (such as taste, color, or odor) in drinking water.

Based upon Coliform Bacteriological Standards, the above results indicate that, at the time the sample was collected, this water sample was safe for drinking purposes.

Caswell Testing & Water Systems, LLC
Phone: 410-557-9355

1111 Oakland Road
email: caswelltesting@verizon.net
MWD 320 MD Lab 328

Freeland, MD 21053
fax: 410-357-5483