

**TENNESSEE DEPARTMENT OF HEALTH AND ENVIRONMENT
PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM**

Issued to: <u>Tyros J. Mc Cormick</u> <small>Owner, Developer, Contractor, Installer, Etc.</small> Location: <u>Nelson Downs S/D</u> <u>Lot #46</u> Installation: <input checked="" type="checkbox"/> 1. New Installation <input type="checkbox"/> 2. Repair to Existing System Establishment: <input checked="" type="checkbox"/> Residential: # Bedrooms <u>3</u> <input type="checkbox"/> 2. Other: _____ <small>(specify)</small> Gal/Day _____	Evaluation Based Upon: <input checked="" type="checkbox"/> 1. Soil typing by Soil Scientist <input type="checkbox"/> 2. Soil Percolation Test <input type="checkbox"/> 3. Environmental Specialist Estimated Absorption Rate: <u>60 at 24"</u> <small>Minutes per inch</small> Conventional Systems: Type of System: <input checked="" type="checkbox"/> 1. Standard <input type="checkbox"/> 2. Alternating <input type="checkbox"/> 3. Chapter _____ <input type="checkbox"/> 4. Other _____	Permit Requirements Based Upon: <input type="checkbox"/> 1. Soil Texture/Structure <input type="checkbox"/> 2. Soil Depth <input type="checkbox"/> 3. Soil Drainage <input type="checkbox"/> 4. Presence of Restrictive Layers <input type="checkbox"/> 5. Position Alternative Systems: <input type="checkbox"/> 1. Low Pressure Pipe <input type="checkbox"/> 2. Mound <input type="checkbox"/> 3. Lagoon <input type="checkbox"/> 4. Large diameter graveless pipe <input type="checkbox"/> 5. Other _____ See attached design package
--	---	---

This system shall consist of a two compartment septic tank holding 1000 gallons, with 330 linear feet in _____ trenches, 36 inches wide and 24" min/max inches deep.

Also required:
☐ 1. Curtain Drain
☐ 2. Flow Diversion Valve
☐ 3. Sewage Pump
☐ 4. Other: _____

All installers of subsurface sewage disposal systems must hold a valid annual license from the Tennessee Department of Health and Environment.

The recipient of this permit agrees to construct or have constructed the above described system in accordance with 68-13-401 et. seq. and The Regulations To Govern Subsurface Sewage Disposal Systems. If any part of the system is covered before being inspected and approved, it shall be uncovered by the recipient of the permit at the direction of personnel of the Department of Health and Environment. Any cutting, filling or alterations of the soil conditions on the aforementioned property after this day may render this approval null and void.

_____ Date 7/2/91
(Signature of Recipient)
 Issued at Murfreesboro Tennessee, in Rutherford County
 By Karen L. Pippin Env. Spec. Date 7-2-91
(Name and Title) (Date of Issue)

This permit is valid for 3 years from date of issue.

Notes

Install 330' of field line in area shaded (see attachment) staying at 24" min/max depth

