



TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES

PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM

<p>Issued to: Rebecca Dodson Owner, Developer, Contractor, Installer, Etc.</p> <p>Location: 9651 Halls Hill Pk. , TN - County: Rutherford Map/Group: 85- Parcel: 17 Subdivision: Lot:</p>	<p>Evaluation Based Upon:</p> <p><input checked="" type="checkbox"/> 1. Soil Typing by Soil Scientist <input type="checkbox"/> a. General <input checked="" type="checkbox"/> b. High Intensity <input type="checkbox"/> c. Extra High Intensity <input type="checkbox"/> 2. Soil Percolation Test <input type="checkbox"/> 3. Environmental Specialist</p> <p>Estimated Absorption Rate: <u>75</u> MPI</p>	<p>Type of System:</p> <p><input checked="" type="checkbox"/> 1. Conventional <input type="checkbox"/> 2. Modified Conventional <input checked="" type="checkbox"/> 3. Conventional System Substitute <input checked="" type="checkbox"/> Chamber <input checked="" type="checkbox"/> Expanded Polystyrene <input type="checkbox"/> Large Diameter Gravelless Pipe Gravel backfill in a 24" wide trench _____ required? <input type="checkbox"/> 4. Low Pressure Pipe <input type="checkbox"/> 5. Mound <input type="checkbox"/> 6. Lagoon <input type="checkbox"/> 7. Subsurface Drip System <input type="checkbox"/> 8. Other</p>
<p>Installation:</p> <p><input checked="" type="checkbox"/> 1. New Installation <input type="checkbox"/> 2. Repair to Existing System <input type="checkbox"/> 3. System Modification</p> <p>Establishment:</p> <p><input checked="" type="checkbox"/> 1. Residential: # Bedrooms <u>4</u> <input type="checkbox"/> 2. Other: _____ Gal/Day <u>0</u></p>	<p>Approval Based Upon: State No. <u>T.C.A. 68-221-403</u></p> <p><input type="checkbox"/> (c) Percolation Test <input type="checkbox"/> (d) Grandfather clause - Current standards except those specified <input type="checkbox"/> (f) 12" (karst) and 6" (non-karst) buffer required</p> <p><input type="checkbox"/> (i) 9" buffer required (24"-36" total soil depth) <input type="checkbox"/> (k) Grandfather clause - meets June 30, 1990 standards (repair only) <input checked="" type="checkbox"/> Current Standards <input type="checkbox"/> Other: _____</p>	

Also required:

- 1. Soil Improvement Practice (SIP)
- Curtain Drain
- Drawdown Drain
- Interceptor Drain
- 2. Flow Diversion Valve
- 3. Sewage Pump
- Pump Flow Rate (gpm) _____
- TDH (ft) _____
- 4. Other: _____

This system shall consist of a two compartment septic tank holding 1000 gallons, with 500 linear feet in 5+ trenches, 36 inches wide and 24 (min) to 24 (max) inches deep. (Depth of gravel: 12 inches)

General Comments: Maintain all proper setbacks
Keep all impacting actions and features outside soil area
Install on contour at min/max depth
No reduction on footage
Retain duplicate area
Call or text information for final inspection 615-762-5153

All installers of subsurface sewage disposal systems must hold a valid annual license from the Tennessee Department of Environment and Conservation.

Please see attached drawing and supporting documentation.

The recipient of this permit agrees to construct or have constructed the above described system in accordance with T.C.A. 68-221-401 et. seq. and The Regulations To Govern Subsurface Sewage Disposal Systems. If any part of the system is covered before inspected and approved, it shall be uncovered by the recipient of the permit at the direction of personnel of the Department of Environment and Conservation. **Any cutting, filling or alterations of the soil conditions on the aforementioned property after this day may render this approval null and void.**

By Mandy Bolzman ES3

Date 12/14/2023

(Date of issue)

This is a permit to construct and is not intended to imply approval of any work proposed or completed on this lot.

Tennessee Department of Environment and Conservation - Division of Water Resources
Permit for Construction of a Subsurface Sewage Disposal System



Issued To: Rebecca Dodson

Location: 9651 Halls Hill Pk.

Map 85 Parcel 17.00

Inspector: Mandy Bolzman *Mandy Bolzman EST*

Date: 12/14/23

General Notes:

- Please refer to the design specifications for the subsurface sewage disposal system on the first page of the construction permit.
- Contact the local Division of Water Resources representative to schedule a final inspection.
- All electric components (e.g., pump, alarm, etc.) for the subsurface sewage disposal system must be inspected and approved by the appropriate electrical inspector prior to requesting a final inspection. Documentation of the electrical inspection must be available during the final inspection.

(4) four bedroom 500' 24" min/max depth

1000 gal septic tank

- Maintain all proper setbacks
- Keep all impacting features and actions outside soil area
- Install on contour at min/max depth
- All soil stakes must be present at installation
- Retain duplicate area
- No reduction on footage
- Call for final inspection and with questions 615-762-5153

