



PERMIT TO INSTALL (Repair) AN ONSITE SEWAGE DISPOSAL SYSTEM

ETOWAH 547-6311 County Health Department 3101041 County Health Department I.D. No.

For Department Use Only
New [X] Repair [ ] Alternative [ ] Other [ ]
This permit: [X] [ ] With Conditions (See Below) [ ] -Reasons:

APPLICANT STEWARD, DIANE Telephone 442-1975

Address/Location RAMSEY ROAD, RAINBOW CITY
City State Zip

SUBDIVISION (if applicable) Plat Block Lot

INSTALL AT THIS SITE: An approved onsite sewage disposal system constructed in compliance with the Onsite Sewage Disposal Rules (Chapter 420-3-1) and the approved plot/construction plan.

- 1. SEPTIC TANK: 1500 gallons (minimum) Other
2. EFFLUENT DISPOSAL FIELD: 1125 square feet consisting of (as appropriate):
375 Linear feet installed in a 36 inch wide trench, and at a depth of 24 inches.
Linear feet of ( ) 8 inch, ( ) 10 inch gravel-less pipe.
Linear feet of total for separate washing machine line (Install balance on main disposal field).
Linear feet added to total if spa/hot tub installed.
TOTAL Linear feet in onsite sewage disposal system.

ADDITIONAL APPROVAL CONDITIONS: 1000 GALLON GREASE TRAP REQUIRED ON KITCHEN TO GO INTO SEPTIC TANK. TO BE INSTALLED IN AREA OF PERC TEST.

03-02-01

Date Issued

Signature Public Health Environmentalist

Approval of this site for the installation and usage of an onsite sewage disposal system is based on, and contingent upon, the certifying professional's soils tests and statements being accurate. This sewage disposal system permit to install is null and void if: (a) conditions are changed from those shown on the application or the approved plot/construction plan; or (b) conditions of this permit are not followed. No part of any installation shall be covered or used until inspected, corrections made (if necessary), and approved by the local health department (unless expressly authorized by the local health department in writing). Any part of the installation which has been covered prior to approval shall be uncovered, if necessary, upon direction by the local health department. NOTE. Effluent lines must be a minimum of 100 feet from any water well or source of potable water, 50 feet from any surface waters, 10 feet from any existing or proposed swimming pool, 5 feet from any property line, and 5 feet from any dwelling. The issuance of this permit is based on the soil test results reported on the application form and is site-specific for the area selected by the engineer/land surveyor/soil classifier/site evaluator.

Issuance of the Permit To Install (Repair) An Onsite Sewage Disposal System, and subsequent approval (if any) of same by representatives of the Alabama Department of Public Health or county health departments, shall not be construed as a guarantee that such systems will function satisfactorily for any given period of time; furthermore, the health department does not assume any liability for damages which are caused, or which may be caused, by the malfunction of such system. The submittal of the Application To Install (Repair) An Onsite Sewage Disposal System assumes that the owner, applicant, or developer has insured that the tract is usable for the installation and usage of an onsite sewage disposal system.