



IMPROVEMENT PERMIT
Beaufort County Health Department

Environmental Health Section
220 North Market St.
Washington NC 27889

Phone: 252-948-8048 Fax: 252-948-2074

For Office Use Only		Page 1 of 2
*CDP File Number:	200290 - 1	
County ID Number:	001334656	
Evaluated For:	NEW	

PERMIT VALID UNTIL: 09 / 11 / 2013

NOTE TO INSPECTIONS DIVISION Building Permits cannot be issued with only an Improvement Permit Fill Sheet CA?

Applicant: Richard Estabrooks Address: 110 Egret Bay City: Washington State/Zip: NC 27889 Phone #: (252) 833-4487	Property Owner: Richard Estabrooks Address: 110 Egret Bay City: Washington State/Zip: NC 27889 Phone #: (252) 833-4487
--	---

Address: 014 Pamlico River Dr Road #: Washington NC 27889 Township:	Property Location & Site Information Subdivision: Pamlico Plantation Phase: Lot: 104 Directions: Hwy 204 W to Douglas Crossroads Rt on HWY 32 1.3 miles left on Harvey Rd 1.7 mile turn right on Pamlico Plantation Dr. go 1.3 miles take 3rd exit on traffic circle take Pamlico river Dr to end
Structure: SINGLE FAMILY # of Bedrooms: 4 # of People: 6 *Water Supply: PUBLIC	

Initial System *Site Classification: Provisionally Suitable Saprotite System? <input type="radio"/> Yes <input checked="" type="radio"/> No Design Flow: 488 Soil Group: II Soil Application Rate: 0.8 *System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS) *Proposed System: CONVENTIONAL	System Specifications Minimum Trench Depth: 18 inches Maximum Trench Depth: 18 inches Fill Depth: inches Septic Tank: 1888 Gallons Pump Required: <input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> May Be Required Pump Tank: Gallons
---	---

Repair System Required Yes No No, but has Available Space

Repair System *Site Classification: Provisionally Suitable Soil Application Rate: 0.8 *System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS) *Proposed System: CONVENTIONAL	System Specifications Minimum Trench Depth: 18 inches Maximum Trench Depth: 18 inches Fill Depth: inches Pump Required: <input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> May Be Required Pump Tank: Gallons
--	---

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.

Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

Permit Conditions 1000gal septic tank, distribution box, all piping and 4 (3' x 50') conventional drainlines as shown on permit; use soil cloth, maintain setbacks; Conventional repair, Construction Authorization to be issued upon approval of final site plan

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plot, or intended use changes (NCGS 136A-302 (g)). The person owning or controlling the system shall be responsible for ensuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting, and repair (136B(b)).

*Authorized State Agent: 2018 - Hager, Matthew *[Signature]* Date of Issue: 09 / 11 / 2018

Owner/Applicant Signature: _____
 Site Plan/Drawing attached.



