


IMPROVEMENTS PERMIT
DAVIDSON COUNTY DEPARTMENT OF PUBLIC HEALTH

Map Code 19-A 3-A
Nº 11624

Owner Barrier Bobby L. Address _____ Structure House
Builder _____ Address _____ Subdivision Tarawood
Location Shore Line Dr. Lot No. 93 Block No. Sec-2
Township _____ Map Number _____
No. Bedrooms 3 No. Occupants 2
Basement _____ Basement Fixtures _____
Septic Tank 1000 Gallons Nitrification Field 900 sq. ft.
No. of Lines 1 Length of Lines 300 ft.
Line Width 36" Stone Depth Under Pipe 6+6"
Lot Area _____ sq. ft. Water Supply _____

Set Back F _____ L _____ B _____ R _____
Lot Size F _____ L _____ B _____ R _____

NOTE: The above are minimum specifications for a sewage disposal system on above captioned property, subject to final approval by the Health Director and compliance with local zoning and building regulations. This layout may not be altered without written permission from a representative of the Davidson County Health Department. Only contractors registered with the Davidson County Health Department may install this system. This permit may be revoked at any time for failure to comply with the existing regulations of the Davidson County Board of Health.



Above information certified by: X Daryl B Leonard
Comments _____

This Permit expires two years from date of issue

Permit Granted ☒ Permit Denied ☐

Sanitarian Charles T. Phillips Sr.

Date 11-6-86


1 R
CERTIFICATE OF COMPLETION
DAVIDSON COUNTY DEPARTMENT OF PUBLIC HEALTH

H. D. Permit # 11624
Map Code 19-A 3-A

ELEC. INSP. REFERRAL

Owner Berrier Bobby L.
Builder _____
Address _____
Location Shore Line Dr.

Structure House
Subdivision TaraWood 9D
Lot No. 33 Block No. _____
No. Bedrooms 3 No. Occupants 2
Basement _____ Basement Fixtures _____
Septic Tank Size 1000 Gallons
Nitrification Field 900 Sq. Ft.
No. of Lines 1 Length of Lines 300 ft.
Line Width 36" Stone Depth Under Pipe 6+6"
Water Supply _____ Distance from Pollution _____
Lot Area _____ F L B R (ft.)
Lot Size _____
Comments _____



Front

Building Permit No. _____
Installer Wafford
Approved ☒ Disapproved ☐
Date 11-6-87
Sanitarian Charles T. Phillips Jr