

Operation Permit

Forsyth County Department of Public Health
Division of Environmental Health and Laboratory
799 Highland Avenue
Winston-Salem, NC 27101
(336) 703-3225



Application _____
Lot 0203 Block 4612
Map Code _____
File 50048
NEW _____ REPAIR ☒
Date 7-28-11

Applicant Warners Chapel Church Installer Frank Transon

Address of Site 7545 Grapevine Rd. Subdivision _____
Directions to Site Lewisville - Vienna Rd. to Grapevine - House on right.

Use of Structure SFD Daily Flow 300 Number of Bedrooms 2
Number of Employees - Number of People 5 Water Supply: Public
LTAR _____ Total Sq. Footage 858 Sys Type II46 Sys Classification IQ4 Aggregate Dpth _____
Total Trench Length 286 ft. Trench Depth 23'-36" in. Trench Width 36"
EHS IP/CA J. Chapple EHS OP J. Chapple

Septic Tank: * New PVC Tee
Manufacturer Existing STB- _____ Gals. _____ Date _____
Filter Brand _____ Filter Model # _____ ST Marker _____
Pump Tank: _____
Manufacturer Shurf PT. 42 One/Two piece Two Gal. 1250
Date 4-11-11 Riser (min. 6") ☒ Riser Sealed Properly ☒ Gal. per inch in Tank 20.5
Pump Requirements:
Alarm Audible ☒ Alarm Visible ☐ Dosing Vol. 130 Draw Down 6 in.
Rope/Stainless Chain Rope GPM 20.5 TDH 8
Supply Line:
Size 2 in. 69 ft. PVC Unions ☒ PVC Ball or Gate Valve ☒ Valves Accessible ☒ Check Valve ☒ Anti-siphon Hole ☐ Vent Hole ☒
Electrical Equipment:
NEMA 4X Box ☒ Box 12 in. above Grade ☒ Box Adj. to Pump Tank ☒ Piggyback Plug ☒ Weatherproof Sealant ☒ Pump Manually Operable ☒ or Equivalent

