

Thompson Heating & Cooling
3700 W Hwy 146
LaGrange, KY 40031



INVOICE
Unpaid

Presented to:
Karen Troth
1424 Garvey Drive
Louisville, KY 40216

Job # 37476
Invoice # I-37476-1
Technician Reid Pratt
Issue Date Dec 10 2018
Payment Terms Upon Receipt
Due Date Dec 10 2018

Customer Contact:
M: (502) 696-4024

Location Address:
1424 Garvey Drive
Louisville, KY 40216

DESCRIPTION	QTY	YOUR PRICE
Furnace inspection	1	\$99.00
	Subtotal	\$99.00
	Taxes	\$0.00
	Total	\$99.00

Pay Now

Sign-up for a Maintenance Plan today!

Invoice Notes:


Customer was concerned about CO at burners. They already had furnace check for season. I did pull blower and visually check heat exchanger: ok. I checked over heating components. Blower bearings are loose, so blower motor blower needs to be replaced. Check gas pressure: 3.55 w.c. I let system run for 20min. No CO at burners or airstream. Furnace is 23 yrs old abs is operational. No warranty due to age of system.

Customer Approval:

I agree to the terms and that the work has been completed to my satisfaction.

Full Name:

Signature:



Signature Date/Time: 12/10/2018 1:12pm